

## **POOR LEGIBILITY**

ONE OR MORE PAGES IN THIS DOCUMENT ARE DIFFICULT TO READ  
DUE TO THE QUALITY OF THE ORIGINAL

## CITY OF MOUNTAIN VIEW

Public Works

October 28, 1970

Sylvania Electric Products Inc.  
P.O. Box 188  
Mountain View, CA 94031

Attention Mr. Ed Dicks, Facilities Planner

RE: INDUSTRIAL WASTES

Dear Mr. Dicks:

The industrial waste treatment facilities proposed for construction on your Drawings 24124-1, 2 and 24125 dated 1-9-70 appear to be adequate and are approved for use with one exception. There is to be installed an interface sensor on the T. E. dropout probe which will look out the lift station pump motor sound an alarm on high level of T.C.E. This information was given to Mr. H. B. Davis via your organization on October 22, 1970.

Mr. Davis was also informed that cyanide in any effluent neutralization was not acceptable in the City's sanitary sewer system. Mr. Davis had previously been so advised on October 2, 1970.

This approval of waste neutralizing facilities for use in no way implies that the City assumes any responsibility for the adequacy of the process or the facility.

It is requested that you notify Mr. Eugene Downs, Superintendent of Public Works at 967-7211, Ext 270 when the facility is fully operational. He will have an inspection made at that time and may also want to receive sampling of effluent and laboratory analyses.

I assume that application is being made for a proper building permit and that a Fire Chief has been notified of the intended usage on site.

Please convey to Mr. Dicks my hope for his speedy

Very truly yours

GREG L. McPHEETERS  
Water Division

MR

CM

DICK DAVIS  
Bldg.

PC

CB

PWS

WDB

T/Y